

January 30, 2024

John Cable  
Triangle  
17855 Elk Prairie Drive  
P.O. Box 1026  
Rolla, MO 65402  
TEL: (573) 364-1864  
FAX: (573) 364-4782



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

**RE: RPS-Rolla High School**

**WorkOrder: 24010251**

Dear John Cable:

TEKLAB, INC received 60 samples on 1/3/2024 12:57:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Marvin L. Darling  
Project Manager  
(618)344-1004 ex 41  
[mdarling@teklabinc.com](mailto:mdarling@teklabinc.com)



## Report Contents

<http://www.teklabinc.com/>

---

**Client:** Triangle

**Work Order:** 24010251

**Client Project:** RPS-Rolla High School

**Report Date:** 30-Jan-24

---

**This reporting package includes the following:**

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Quality Control Results	9
Receiving Check List	12
Chain of Custody	Appended

**Client:** Triangle

**Work Order:** 24010251

**Client Project:** RPS-Rolla High School

**Report Date:** 30-Jan-24

### Abbr Definition

\* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

**Client:** Triangle

**Work Order:** 24010251

**Client Project:** RPS-Rolla High School

**Report Date:** 30-Jan-24

### Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)



## Case Narrative

<http://www.teklabinc.com/>

**Client:** Triangle

**Work Order:** 24010251

**Client Project:** RPS-Rolla High School

**Report Date:** 30-Jan-24

**Cooler Receipt Temp:** N/A °C

### Locations

#### Collinsville

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425

**Phone** (618) 344-1004

**Fax** (618) 344-1005

**Email** jhriley@teklabinc.com

#### Collinsville Air

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425

**Phone** (618) 344-1004

**Fax** (618) 344-1005

**Email** EHurley@teklabinc.com

#### Springfield

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415

**Phone** (217) 698-1004

**Fax** (217) 698-1005

**Email** KKlostermann@teklabinc.com

#### Chicago

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515

**Phone** (630) 324-6855

**Fax**

**Email** arenner@teklabinc.com

#### Kansas City

**Address** 8421 Nieman Road  
Lenexa, KS 66214

**Phone** (913) 541-1998

**Fax** (913) 541-1998

**Email** jhriley@teklabinc.com



## Accreditations

<http://www.teklabinc.com/>

**Client:** Triangle

**Work Order:** 24010251

**Client Project:** RPS-Rolla High School

**Report Date:** 30-Jan-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



# Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010251

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>									
<b>Lead</b>									
24010251-001A	61-A	NELAP		0.0010	<b>0.0218</b>	mg/L	1	01/19/2024 18:15	12/30/2023 10:00
24010251-002A	61-B	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/19/2024 18:19	12/30/2023 10:00
24010251-003A	62-A	NELAP		0.0010	<b>0.0097</b>	mg/L	1	01/19/2024 18:23	12/30/2023 10:00
24010251-004A	62-B	NELAP		0.0010	<b>0.0033</b>	mg/L	1	01/18/2024 19:54	12/30/2023 10:00
24010251-005A	63-A	NELAP		0.0010	<b>0.0251</b>	mg/L	5	01/26/2024 3:35	12/30/2023 10:00
24010251-006A	63-B	NELAP		0.0010	<b>0.0038</b>	mg/L	1	01/18/2024 19:58	12/30/2023 10:00
24010251-007A	64-A	NELAP		0.0010	<b>0.0066</b>	mg/L	1	01/19/2024 18:27	12/30/2023 10:00
24010251-008A	64-B	NELAP		0.0010	<b>0.0030</b>	mg/L	1	01/19/2024 18:31	12/30/2023 10:00
24010251-009A	65-A	NELAP		0.0010	<b>0.0101</b>	mg/L	1	01/19/2024 18:35	12/30/2023 10:00
24010251-010A	65-B	NELAP		0.0010	<b>0.0090</b>	mg/L	1	01/19/2024 18:39	12/30/2023 10:00
24010251-011A	66-A	NELAP		0.0010	<b>0.0388</b>	mg/L	5	01/26/2024 3:39	12/30/2023 10:00
24010251-012A	66-B	NELAP		0.0010	<b>0.0042</b>	mg/L	1	01/19/2024 18:43	12/30/2023 10:00
24010251-013A	67-A	NELAP		0.0010	<b>0.0116</b>	mg/L	1	01/18/2024 12:05	12/30/2023 10:00
24010251-014A	67-B	NELAP		0.0010	<b>0.0025</b>	mg/L	1	01/18/2024 12:08	12/30/2023 10:00
24010251-015A	68-A	NELAP		0.0010	<b>0.0120</b>	mg/L	1	01/18/2024 12:12	12/30/2023 10:00
24010251-016A	68-B	NELAP		0.0010	<b>0.0030</b>	mg/L	1	01/18/2024 12:16	12/30/2023 10:00
24010251-017A	69-A	NELAP		0.0010	<b>0.0105</b>	mg/L	1	01/19/2024 23:43	12/30/2023 10:00
24010251-018A	69-B	NELAP		0.0010	<b>0.0038</b>	mg/L	5	01/26/2024 3:44	12/30/2023 10:00
24010251-019A	70-A	NELAP		0.0010	<b>0.0157</b>	mg/L	1	01/18/2024 12:41	12/30/2023 10:00
24010251-020A	70-B	NELAP		0.0010	<b>0.0033</b>	mg/L	1	01/23/2024 10:27	12/30/2023 10:00
24010251-021A	71-A	NELAP		0.0010	<b>0.0326</b>	mg/L	1	01/18/2024 12:49	12/30/2023 10:00
24010251-022A	71-B	NELAP		0.0010	<b>0.0084</b>	mg/L	1	01/18/2024 12:52	12/30/2023 10:00
24010251-023A	72-A	NELAP		0.0010	<b>0.0165</b>	mg/L	1	01/18/2024 12:56	12/30/2023 10:00
24010251-024A	72-B	NELAP		0.0010	<b>0.0188</b>	mg/L	5	01/26/2024 3:48	12/30/2023 10:00
24010251-025A	73-A	NELAP		0.0010	<b>0.0157</b>	mg/L	1	01/18/2024 13:00	12/30/2023 10:00
24010251-026A	73-B	NELAP		0.0010	<b>0.0034</b>	mg/L	1	01/18/2024 13:03	12/30/2023 10:00
24010251-027A	74-A	NELAP		0.0010	<b>0.0156</b>	mg/L	1	01/18/2024 13:25	12/30/2023 10:00
24010251-028A	74-B	NELAP		0.0010	<b>0.0058</b>	mg/L	5	01/30/2024 9:27	12/30/2023 10:00
24010251-029A	75-A	NELAP		0.0010	<b>0.0203</b>	mg/L	5	01/26/2024 3:52	12/30/2023 10:00
24010251-030A	75-B	NELAP		0.0010	<b>0.0048</b>	mg/L	5	01/26/2024 3:56	12/30/2023 10:00
24010251-031A	76-A	NELAP		0.0010	<b>0.0167</b>	mg/L	5	01/26/2024 4:25	12/30/2023 10:00
24010251-032A	76-B	NELAP		0.0010	<b>0.0026</b>	mg/L	5	01/26/2024 4:49	12/30/2023 10:00
24010251-033A	77-A	NELAP		0.0010	<b>0.0053</b>	mg/L	1	01/18/2024 13:29	12/30/2023 10:00
24010251-034A	77-B	NELAP		0.0010	<b>0.0011</b>	mg/L	1	01/18/2024 13:33	12/30/2023 10:00
24010251-035A	78-A	NELAP		0.0010	<b>0.0167</b>	mg/L	5	01/26/2024 4:29	12/30/2023 10:00
24010251-036A	78-B	NELAP		0.0010	<b>0.0057</b>	mg/L	1	01/18/2024 13:36	12/30/2023 10:00
24010251-037A	79-A	NELAP		0.0010	<b>0.0166</b>	mg/L	1	01/18/2024 13:40	12/30/2023 10:00
24010251-038A	79-B	NELAP		0.0010	<b>0.0030</b>	mg/L	1	01/24/2024 9:08	12/30/2023 10:00
24010251-039A	80-A	NELAP		0.0010	<b>0.0144</b>	mg/L	1	01/18/2024 13:55	12/30/2023 10:00
24010251-040A	80-B	NELAP		0.0010	<b>0.0018</b>	mg/L	1	01/18/2024 14:09	12/30/2023 10:00
24010251-041A	81-A	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/15/2024 13:49	12/30/2023 10:00
24010251-042A	81-B	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/15/2024 13:53	12/30/2023 10:00
24010251-043A	82-A	NELAP		0.0010	<b>0.0034</b>	mg/L	1	01/15/2024 13:56	12/30/2023 10:00
24010251-044A	82-B	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/17/2024 10:25	12/30/2023 10:00
24010251-045A	83-A	NELAP		0.0010	<b>0.0017</b>	mg/L	1	01/16/2024 12:42	12/30/2023 10:00
24010251-046A	83-B	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/16/2024 12:46	12/30/2023 10:00
24010251-047A	84-A	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/16/2024 12:50	12/30/2023 10:00
24010251-048A	84-B	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/16/2024 12:54	12/30/2023 10:00



## Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010251

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>									
<b>Lead</b>									
24010251-049A	85-A	NELAP		0.0010	<b>0.0014</b>	mg/L	1	01/16/2024 12:59	12/30/2023 10:00
24010251-050A	85-B	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/17/2024 10:42	12/30/2023 10:00
24010251-051A	86-A	NELAP		0.0010	<b>0.0024</b>	mg/L	1	01/16/2024 13:03	12/30/2023 10:00
24010251-052A	86-B	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/16/2024 13:07	12/30/2023 10:00
24010251-053A	87-A	NELAP		0.0010	<b>0.0042</b>	mg/L	1	01/16/2024 13:36	12/30/2023 10:00
24010251-054A	87-B	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/16/2024 13:40	12/30/2023 10:00
24010251-055A	88-A	NELAP		0.0010	<b>0.0099</b>	mg/L	1	01/16/2024 13:44	12/30/2023 10:00
24010251-056A	88-B	NELAP		0.0010	<b>0.0011</b>	mg/L	1	01/16/2024 13:48	12/30/2023 10:00
24010251-057A	89-A	NELAP		0.0010	<b>0.0046</b>	mg/L	1	01/16/2024 13:52	12/30/2023 10:00
24010251-058A	89-B	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/16/2024 13:56	12/30/2023 10:00
24010251-059A	90-A	NELAP		0.0010	<b>0.0129</b>	mg/L	1	01/16/2024 14:00	12/30/2023 10:00
24010251-060A	90-B	NELAP		0.0010	< <b>0.0010</b>	mg/L	1	01/16/2024 14:37	12/30/2023 10:00





## Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010251

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

### EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216944		SampType: MS		Units mg/L							Date Analyzed
SampID: 24010251-006AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		<b>0.0990</b>	0.1000	0.003808	95.2	70	130	01/18/2024	

Batch 216944		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 24010251-006AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010	E	<b>0.100</b>	0.1000	0.003808	96.5	0.09898	1.37	01/18/2024		

Batch 216944		SampType: MS		Units mg/L							Date Analyzed
SampID: 24010251-017AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	<b>0.101</b>	0.1000	0.01047	90.2	70	130	01/19/2024	

Batch 216944		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 24010251-017AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010		<b>0.0974</b>	0.1000	0.01047	86.9	0.1007	3.36	01/19/2024		

Batch 216945		SampType: MS		Units mg/L							Date Analyzed
SampID: 24010251-026AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		<b>0.0968</b>	0.1000	0.003434	93.4	70	130	01/18/2024	

Batch 216945		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 24010251-026AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010		<b>0.0858</b>	0.1000	0.003434	82.3	0.09679	12.07	01/18/2024		

Batch 216945		SampType: MS		Units mg/L							Date Analyzed
SampID: 24010251-038AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	<b>0.114</b>	0.1000	0.002978	111.1	70	130	01/24/2024	

Batch 216945		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 24010251-038AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010	E	<b>0.110</b>	0.1000	0.002978	107.4	0.1141	3.24	01/24/2024		



## Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010251

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

### EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216971		SampType: MBLK		Units mg/L							
SampID: MBLK-216971											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/15/2024	

Batch 216971		SampType: LCS		Units mg/L							
SampID: LCS-216971											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0504	0.0500	0	100.9	85	115	01/15/2024	

Batch 216971		SampType: MS		Units mg/L							
SampID: 24010251-044AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0969	0.1000	0	96.9	70	130	01/17/2024	

Batch 216971		SampType: MSD		Units mg/L							
SampID: 24010251-044AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0960	0.1000	0	96.0	0.09689	0.88	01/17/2024	

Batch 216971		SampType: MS		Units mg/L							
SampID: 24010251-050AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0978	0.1000	0	97.8	70	130	01/17/2024	

Batch 216971		SampType: MSD		Units mg/L							
SampID: 24010251-050AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0988	0.1000	0	98.8	0.09778	0.99	01/17/2024	

Batch 217640		SampType: MBLK		Units mg/L							
SampID: MBLK-217640											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/26/2024	

Batch 217640		SampType: LCS		Units mg/L							
SampID: LCS-217640											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.476	0.5000	0	95.2	85	115	01/26/2024	



## Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010251

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

### EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 217640		SampType: MS		Units mg/L							Date Analyzed
SampID: 24010250-048AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		<b>0.459</b>	0.5000	0.002802	91.3	70	130	01/26/2024	

Batch 217640		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 24010250-048AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010		<b>0.468</b>	0.5000	0.002802	93.0	0.4595	1.81	01/26/2024		

Batch 217640		SampType: MS		Units mg/L							Date Analyzed
SampID: 24010251-032AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	<b>0.891</b>	1.000	0.002569	88.9	70	130	01/26/2024	

Batch 217640		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 24010251-032AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010	E	<b>0.931</b>	1.000	0.002569	92.9	0.8914	4.38	01/26/2024		

Batch 217894		SampType: MBLK		Units mg/L							Date Analyzed
SampID: MBLK-217894											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		<b>&lt; 0.0010</b>	0.0002	0	0	-100	100	01/29/2024	

Batch 217894		SampType: LCS		Units mg/L							Date Analyzed
SampID: LCS-217894											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		<b>0.531</b>	0.5000	0	106.2	85	115	01/29/2024	



# Receiving Check List

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010251

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

Carrier: John Cable

Received By: LEH

Completed by:

*Amber Dilallo*

Reviewed by:

*Ellie Hopkins*

On:

03-Jan-24

Amber Dilallo

On:

03-Jan-24

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

- |   |  |                              |                                      |                                     |                          |
|---|--|------------------------------|--------------------------------------|-------------------------------------|--------------------------|
| Shipping container/cooler in good condition?            | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  | Not Present <input type="checkbox"/> | Temp °C                             | N/A                      |
| Type of thermal preservation?                           | None <input checked="" type="checkbox"/> | Ice <input type="checkbox"/> | Blue Ice <input type="checkbox"/>    | Dry Ice                             | <input type="checkbox"/> |
| Chain of custody present?                               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Chain of custody agrees with sample labels?             | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Samples in proper container/bottle?                     | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Sample containers intact?                               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Sufficient sample volume for indicated test?            | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| All samples received within holding time?               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Reported field parameters measured:                     | Field <input type="checkbox"/>           | Lab <input type="checkbox"/> | NA                                   | <input checked="" type="checkbox"/> |                          |
| Container/Temp Blank temperature in compliance?         | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |

*When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.*

- |   |   |                             |                   |                                     |
|---|---|-----------------------------|-------------------|-------------------------------------|
| Water – at least one vial per sample has zero headspace?  | Yes <input type="checkbox"/>            | No <input type="checkbox"/> | No VOA vials      | <input checked="" type="checkbox"/> |
| Water - TOX containers have zero headspace?               | Yes <input type="checkbox"/>            | No <input type="checkbox"/> | No TOX containers | <input checked="" type="checkbox"/> |
| Water - pH acceptable upon receipt?                       | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | NA                | <input type="checkbox"/>            |
| NPDES/CWA TCN interferences checked/treated in the field? | Yes <input type="checkbox"/>            | No <input type="checkbox"/> | NA                | <input checked="" type="checkbox"/> |

**Any No responses must be detailed below or on the COC.**

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.



24010249

001	1-A	DRINKING WATER	LEAD	12/30/23 @ 1000
002	1-B	DRINKING WATER	LEAD	12/30/23 @ 1000
003	2-A	DRINKING WATER	LEAD	12/30/23 @ 1000
004	2-B	DRINKING WATER	LEAD	12/30/23 @ 1000
005	3-A	DRINKING WATER	LEAD	12/30/23 @ 1000
006	3-B	DRINKING WATER	LEAD	12/30/23 @ 1000
007	4-A	DRINKING WATER	LEAD	12/30/23 @ 1000
008	4-B	DRINKING WATER	LEAD	12/30/23 @ 1000
009	5-A	DRINKING WATER	LEAD	12/30/23 @ 1000
010	5-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	6-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	6-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	7-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	7-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	8-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	8-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	9-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	9-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	10-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	10-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	11-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	11-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	12-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	12-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	13-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	13-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	14-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	14-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	15-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	15-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	16-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	16-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	17-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	17-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	18-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	18-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	19-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	19-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	20-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	20-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	21-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	21-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	22-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	22-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	23-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	23-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	24-A	DRINKING WATER	LEAD	12/30/23 @ 1000

241010249

048	24-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	25-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	25-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	26-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	26-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	27-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	27-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	28-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	28-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	29-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	29-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	30-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	30-B	DRINKING WATER	LEAD	12/30/23 @ 1000
<u>24010250</u>	31-A	DRINKING WATER	LEAD	12/30/23 @ 1000
002	31-B	DRINKING WATER	LEAD	12/30/23 @ 1000
003	32-A	DRINKING WATER	LEAD	12/30/23 @ 1000
004	32-B	DRINKING WATER	LEAD	12/30/23 @ 1000
005	33-A	DRINKING WATER	LEAD	12/30/23 @ 1000
006	33-B	DRINKING WATER	LEAD	12/30/23 @ 1000
007	34-A	DRINKING WATER	LEAD	12/30/23 @ 1000
008	34-B	DRINKING WATER	LEAD	12/30/23 @ 1000
009	35-A	DRINKING WATER	LEAD	12/30/23 @ 1000
010	35-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	36-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	36-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	37-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	37-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	38-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	38-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	39-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	39-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	40-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	40-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	41-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	41-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	42-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	42-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	43-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	43-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	44-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	44-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	45-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	45-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	46-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	46-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	47-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	47-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010250

035	48-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	48-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	49-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	49-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	50-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	50-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	51-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	51-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	52-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	52-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	53-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	53-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	54-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	54-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	55-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	55-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	56-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	56-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	57-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	57-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	58-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	58-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	59-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	59-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	60-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	60-B	DRINKING WATER	LEAD	12/30/23 @ 1000
061	61-A	DRINKING WATER	LEAD	12/30/23 @ 1000
062	61-B	DRINKING WATER	LEAD	12/30/23 @ 1000
063	62-A	DRINKING WATER	LEAD	12/30/23 @ 1000
064	62-B	DRINKING WATER	LEAD	12/30/23 @ 1000
065	63-A	DRINKING WATER	LEAD	12/30/23 @ 1000
066	63-B	DRINKING WATER	LEAD	12/30/23 @ 1000
067	64-A	DRINKING WATER	LEAD	12/30/23 @ 1000
068	64-B	DRINKING WATER	LEAD	12/30/23 @ 1000
069	65-A	DRINKING WATER	LEAD	12/30/23 @ 1000
070	65-B	DRINKING WATER	LEAD	12/30/23 @ 1000
071	66-A	DRINKING WATER	LEAD	12/30/23 @ 1000
072	66-B	DRINKING WATER	LEAD	12/30/23 @ 1000
073	67-A	DRINKING WATER	LEAD	12/30/23 @ 1000
074	67-B	DRINKING WATER	LEAD	12/30/23 @ 1000
075	68-A	DRINKING WATER	LEAD	12/30/23 @ 1000
076	68-B	DRINKING WATER	LEAD	12/30/23 @ 1000
077	69-A	DRINKING WATER	LEAD	12/30/23 @ 1000
078	69-B	DRINKING WATER	LEAD	12/30/23 @ 1000
079	70-A	DRINKING WATER	LEAD	12/30/23 @ 1000
080	70-B	DRINKING WATER	LEAD	12/30/23 @ 1000
081	71-A	DRINKING WATER	LEAD	12/30/23 @ 1000
082	71-B	DRINKING WATER	LEAD	12/30/23 @ 1000



241010251

013 72-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014 72-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015 73-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016 73-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027 74-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028 74-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029 75-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030 75-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031 76-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032 76-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033 77-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034 77-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035 78-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036 78-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037 79-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038 79-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039 80-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040 80-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041 81-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042 81-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043 82-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044 82-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045 83-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046 83-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047 84-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048 84-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049 85-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050 85-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051 86-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052 86-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053 87-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054 87-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055 88-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056 88-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057 89-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058 89-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059 90-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060 90-B	DRINKING WATER	LEAD	12/30/23 @ 1000

241010252

001 91-A	DRINKING WATER	LEAD	12/30/23 @ 1000
002 91-B	DRINKING WATER	LEAD	12/30/23 @ 1000
003 92-A	DRINKING WATER	LEAD	12/30/23 @ 1000
004 92-B	DRINKING WATER	LEAD	12/30/23 @ 1000
005 93-A	DRINKING WATER	LEAD	12/30/23 @ 1000
006 93-B	DRINKING WATER	LEAD	12/30/23 @ 1000
007 94-A	DRINKING WATER	LEAD	12/30/23 @ 1000
008 94-B	DRINKING WATER	LEAD	12/30/23 @ 1000
009 95-A	DRINKING WATER	LEAD	12/30/23 @ 1000

24010252

010	95-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	96-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	96-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	97-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	97-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	98-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	98-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	99-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	99-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	100-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	100-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	101-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	101-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	102-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	102-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	103-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	103-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	104-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	104-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	105-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	105-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	106-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	106-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	107-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	107-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	108-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	108-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	109-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	109-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	110-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	110-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	111-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	111-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	112-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	112-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	113-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	113-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	114-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	114-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	115-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	115-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	116-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	116-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	117-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	117-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	118-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	118-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010252

05)	119-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
058	119-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
059	120-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
<del>060</del>	<del>120-B</del>	<del>DRINKING WATER</del>	<del>LEAD</del>	<del>12/30/23 @ 1000</del>	
24010253	001	121-A	DRINKING WATER	LEAD	12/30/23 @ 1000
001	121-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
003	122-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
004	122-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
005	123-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
006	123-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
007	124-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
008	124-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
009	125-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
010	125-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
011	126-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
012	126-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
013	127-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
014	127-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
015	128-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
016	128-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
017	129-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
018	129-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
019	130-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
020	130-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
021	131-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
022	131-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
023	132-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
024	132-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
025	133-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
026	133-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
027	134-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
028	134-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
029	135-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
030	135-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
031	136-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
032	136-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
033	137-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
034	137-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
035	138-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
036	138-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
037	139-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
038	139-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
039	140-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
040	140-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
041	141-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
042	141-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
043	142-A	DRINKING WATER	LEAD	12/30/23 @ 1000	

24010253

044	142-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	143-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	143-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	144-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	144-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	145-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	145-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	146-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	146-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	147-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	147-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	148-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	148-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	149-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	149-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	150-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	150-B	DRINKING WATER	LEAD	12/30/23 @ 1000
4010254	151-A	DRINKING WATER	LEAD	12/30/23 @ 1000
002	151-B	DRINKING WATER	LEAD	12/30/23 @ 1000
003	152-A	DRINKING WATER	LEAD	12/30/23 @ 1000
004	152-B	DRINKING WATER	LEAD	12/30/23 @ 1000
005	153-A	DRINKING WATER	LEAD	12/30/23 @ 1000
006	153-B	DRINKING WATER	LEAD	12/30/23 @ 1000
007	154-A	DRINKING WATER	LEAD	12/30/23 @ 1000
008	154-B	DRINKING WATER	LEAD	12/30/23 @ 1000
009	155-A	DRINKING WATER	LEAD	12/30/23 @ 1000
010	155-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	156-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	156-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	157-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	157-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	158-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	158-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	159-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	159-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	160-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	160-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	161-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	161-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	162-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	162-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	163-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	163-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	164-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	164-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	165-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	165-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010254

031	166-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	166-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	167-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	167-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	168-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	168-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	169-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	169-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	170-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	170-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	171-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	171-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	172-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	172-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	173-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	173-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	174-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	174-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	175-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	175-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	176-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	176-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	ICE-1	DRINKING WATER	LEAD	12/30/23 @ 1000
054	ICE-2	DRINKING WATER	LEAD	12/30/23 @ 1000