

January 12, 2024

John Cable
Triangle
17855 Elk Prairie Drive
P.O. Box 1026
Rolla, MO 65402
TEL: (573) 364-1864
FAX: (573) 364-4782



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: RPS-Rolla Middle School

WorkOrder: 23122018

Dear John Cable:

TEKLAB, INC received 62 samples on 12/27/2023 2:30:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Marvin L. Darling
Project Manager
(618)344-1004 ex 41
mdarling@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Quality Control Results	9
Receiving Check List	13
Chain of Custody	Appended

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

Cooler Receipt Temp: N/A °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com



Accreditations

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
23122018-001A	32-A	NELAP		0.0010	0.0012	mg/L	1	01/12/2024 1:31	12/23/2023 10:00
23122018-002A	32-B	NELAP		0.0010	0.0015	mg/L	1	01/12/2024 1:40	12/23/2023 10:00
23122018-003A	33-A	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 1:35	12/23/2023 10:00
23122018-004A	33-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 2:04	12/23/2023 10:00
23122018-005A	34-A	NELAP		0.0010	0.0015	mg/L	1	01/12/2024 2:09	12/23/2023 10:00
23122018-006A	34-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 2:13	12/23/2023 10:00
23122018-007A	35-A	NELAP		0.0010	0.0017	mg/L	1	01/12/2024 2:17	12/23/2023 10:00
23122018-008A	35-B	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 11:34	12/23/2023 10:00
23122018-009A	36-A	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 11:38	12/23/2023 10:00
23122018-010A	36-B	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 11:42	12/23/2023 10:00
23122018-011A	37-A	NELAP		0.0010	0.0027	mg/L	1	01/10/2024 11:46	12/23/2023 10:00
23122018-012A	37-B	NELAP		0.0010	0.0011	mg/L	1	01/10/2024 11:50	12/23/2023 10:00
23122018-013A	38-A	NELAP		0.0010	0.0018	mg/L	1	01/10/2024 12:28	12/23/2023 10:00
23122018-014A	38-B	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 12:32	12/23/2023 10:00
23122018-015A	39-A	NELAP		0.0010	0.0045	mg/L	1	01/10/2024 12:36	12/23/2023 10:00
23122018-016A	39-B	NELAP		0.0010	0.0024	mg/L	1	01/10/2024 12:40	12/23/2023 10:00
23122018-017A	40-A	NELAP		0.0010	0.0038	mg/L	1	01/10/2024 12:53	12/23/2023 10:00
23122018-018A	40-B	NELAP		0.0010	0.0013	mg/L	1	01/10/2024 12:45	12/23/2023 10:00
23122018-019A	41-A	NELAP		0.0010	0.0023	mg/L	1	01/10/2024 12:49	12/23/2023 10:00
23122018-020A	41-B	NELAP		0.0010	0.0021	mg/L	1	01/10/2024 13:18	12/23/2023 10:00
23122018-021A	42-A	NELAP		0.0010	0.0014	mg/L	1	01/10/2024 13:22	12/23/2023 10:00
23122018-022A	42-B	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 13:46	12/23/2023 10:00
23122018-023A	43-A	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 13:26	12/23/2023 10:00
23122018-024A	43-B	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 13:30	12/23/2023 10:00
23122018-025A	44-A	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 13:34	12/23/2023 10:00
23122018-026A	44-B	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 13:38	12/23/2023 10:00
23122018-027A	45-A	NELAP		0.0010	0.0015	mg/L	1	01/10/2024 13:42	12/23/2023 10:00
23122018-028A	45-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 2:21	12/23/2023 10:00
23122018-029A	46-A	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 2:25	12/23/2023 10:00
23122018-030A	46-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 2:29	12/23/2023 10:00
23122018-031A	47-A	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 2:58	12/23/2023 10:00
23122018-032A	47-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 3:02	12/23/2023 10:00
23122018-033A	48-A	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 3:06	12/23/2023 10:00
23122018-034A	48-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 3:10	12/23/2023 10:00
23122018-035A	49-A	NELAP		0.0010	0.0051	mg/L	1	01/12/2024 3:15	12/23/2023 10:00
23122018-036A	49-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 3:19	12/23/2023 10:00
23122018-037A	50-A	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 2:33	12/23/2023 10:00
23122018-038A	50-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 3:23	12/23/2023 10:00
23122018-039A	51-A	NELAP		0.0010	0.0021	mg/L	1	01/12/2024 3:52	12/23/2023 10:00
23122018-040A	51-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 3:56	12/23/2023 10:00
23122018-041A	52-A	NELAP		0.0010	0.0045	mg/L	1	01/12/2024 4:00	12/23/2023 10:00
23122018-042A	52-B	NELAP		0.0010	0.0021	mg/L	1	01/12/2024 3:27	12/23/2023 10:00
23122018-043A	53-A	NELAP		0.0010	0.0534	mg/L	1	01/12/2024 4:04	12/23/2023 10:00
23122018-044A	53-B	NELAP		0.0010	0.0109	mg/L	5	01/05/2024 19:38	12/23/2023 10:00
23122018-045A	54-A	NELAP		0.0010	0.0255	mg/L	1	01/12/2024 4:08	12/23/2023 10:00
23122018-046A	54-B	NELAP		0.0010	0.0030	mg/L	1	01/12/2024 4:12	12/23/2023 10:00
23122018-047A	55-A	NELAP		0.0010	0.0452	mg/L	1	01/12/2024 4:16	12/23/2023 10:00
23122018-048A	55-B	NELAP		0.0010	0.0050	mg/L	1	01/12/2024 4:21	12/23/2023 10:00



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
23122018-049A	56-A	NELAP		0.0010	0.0227	mg/L	1	01/12/2024 4:25	12/23/2023 10:00
23122018-050A	56-B	NELAP		0.0010	0.0069	mg/L	5	01/05/2024 19:43	12/23/2023 10:00
23122018-051A	57-A	NELAP		0.0050	0.0090	mg/L	5	01/12/2024 9:42	12/23/2023 10:00
23122018-052A	57-B	NELAP		0.0010	0.0096	mg/L	1	01/12/2024 4:54	12/23/2023 10:00
23122018-053A	58-A	NELAP		0.0010	0.0707	mg/L	1	01/12/2024 4:58	12/23/2023 10:00
23122018-054A	58-B	NELAP		0.0010	0.0101	mg/L	1	01/12/2024 5:23	12/23/2023 10:00
23122018-055A	59-A	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 5:02	12/23/2023 10:00
23122018-056A	59-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 5:06	12/23/2023 10:00
23122018-057A	60-A	NELAP		0.0010	0.0029	mg/L	1	01/12/2024 5:10	12/23/2023 10:00
23122018-058A	60-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 5:14	12/23/2023 10:00
23122018-059A	61-A	NELAP		0.0010	0.0016	mg/L	1	01/12/2024 5:19	12/23/2023 10:00
23122018-060A	61-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 5:48	12/23/2023 10:00
23122018-061A	62-A	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 5:52	12/23/2023 10:00
23122018-062A	62-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 5:56	12/23/2023 10:00



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216726		SampType: MBLK		Units mg/L						
SampID: MBLK-216726										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/05/2024

Batch 216726		SampType: LCS		Units mg/L						
SampID: LCS-216726										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0477	0.0500	0	95.4	85	115	01/05/2024

Batch 216726		SampType: MS		Units mg/L						
SampID: 23122018-017AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010	E	0.104	0.1000	0.003843	100.6	70	130	01/10/2024

Batch 216726		SampType: MSD		Units mg/L						
SampID: 23122018-017AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010	E	0.103	0.1000	0.003843	98.8	0.1044	1.70	01/10/2024

Batch 216726		SampType: MS		Units mg/L						
SampID: 23122018-022AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010	E	0.102	0.1000	0.0003467	101.3	70	130	01/10/2024

Batch 216726		SampType: MSD		Units mg/L						
SampID: 23122018-022AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010		0.0955	0.1000	0.0003467	95.2	0.1017	6.22	01/10/2024

Batch 216728		SampType: MBLK		Units mg/L						
SampID: MBLK-216728										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/11/2024

Batch 216728		SampType: LCS		Units mg/L						
SampID: LCS-216728										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0527	0.0500	0	105.4	85	115	01/11/2024



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216728		SampType: MS		Units mg/L							
SampID: 23122012-034AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.116	0.1000	0.0002596	115.8	70	130	01/12/2024	

Batch 216728		SampType: MSD		Units mg/L							
SampID: 23122012-034AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.113	0.1000	0.0002596	113.2	0.1160	2.25	01/12/2024	

Batch 216728		SampType: MS		Units mg/L							
SampID: 23122018-002AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.118	0.1000	0.001451	116.4	70	130	01/12/2024	

Batch 216728		SampType: MSD		Units mg/L							
SampID: 23122018-002AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.119	0.1000	0.001451	117.8	0.1179	1.16	01/12/2024	

Batch 216730		SampType: MBLK		Units mg/L							
SampID: MBLK-216730											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/11/2024	

Batch 216730		SampType: LCS		Units mg/L							
SampID: LCS-216730											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0527	0.0500	0	105.4	85	115	01/11/2024	

Batch 216730		SampType: MS		Units mg/L							
SampID: 23122018-037AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.116	0.1000	0.0007102	114.8	70	130	01/12/2024	

Batch 216730		SampType: MSD		Units mg/L							
SampID: 23122018-037AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.117	0.1000	0.0007102	116.1	0.1155	1.12	01/12/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216730		SampType: MS		Units mg/L							
SampID: 23122018-042AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.121	0.1000	0.002071	118.7	70	130	01/12/2024	

Batch 216730		SampType: MSD		Units mg/L							
SampID: 23122018-042AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.117	0.1000	0.002071	114.9	0.1207	3.15	01/12/2024	

Batch 216731		SampType: MBLK		Units mg/L							
SampID: MBLK-216731											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/11/2024	

Batch 216731		SampType: LCS		Units mg/L							
SampID: LCS-216731											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0527	0.0500	0	105.4	85	115	01/11/2024	

Batch 216731		SampType: MS		Units mg/L							
SampID: 23122018-054AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.128	0.1000	0.01006	117.5	70	130	01/12/2024	

Batch 216731		SampType: MSD		Units mg/L							
SampID: 23122018-054AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.130	0.1000	0.01006	120.3	0.1276	2.15	01/12/2024	

Batch 216731		SampType: MS		Units mg/L							
SampID: 23122019-001AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.125	0.1000	0.01429	111.0	70	130	01/12/2024	

Batch 216731		SampType: MSD		Units mg/L							
SampID: 23122019-001AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.125	0.1000	0.01429	111.2	0.1253	0.18	01/12/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216831 **SampType: MBLK** Units mg/L

SampleID: MBLK-216831

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/05/2024

Batch 216831 **SampType: LCS** Units mg/L

SampleID: LCS-216831

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.497	0.5000	0	99.4	85	115	01/05/2024

Batch 216831 **SampType: MS** Units mg/L

SampleID: 23121869-069AMS

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.484	0.5000	0.001288	96.6	70	130	01/05/2024

Batch 216831 **SampType: MSD** Units mg/L

SampleID: 23121869-069AMSD

RPD Limit: 20

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010		0.453	0.5000	0.001288	90.4	0.4845	6.68	01/05/2024

Batch 216831 **SampType: MS** Units mg/L

SampleID: 23122019-019AMS

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.480	0.5000	0.06922	82.2	70	130	01/05/2024

Batch 216831 **SampType: MSD** Units mg/L

SampleID: 23122019-019AMSD

RPD Limit: 20

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010	E	0.544	0.5000	0.06922	94.9	0.4802	12.41	01/05/2024



Receiving Check List

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122018

Client Project: RPS-Rolla Middle School

Report Date: 12-Jan-24

Carrier: John Cable

Received By: LEH

Completed by:

Amber Dilallo

Reviewed by:

Ellie Hopkins

On:

28-Dec-23

Amber Dilallo

On:

28-Dec-23

Ellie Hopkins

Pages to follow:

Chain of custody

Extra pages included

- | | | | | | |
|---|--|------------------------------|--------------------------------------|-------------------------------------|--------------------------|
| Shipping container/cooler in good condition? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | Not Present <input type="checkbox"/> | Temp °C | N/A |
| Type of thermal preservation? | None <input checked="" type="checkbox"/> | Ice <input type="checkbox"/> | Blue Ice <input type="checkbox"/> | Dry Ice | <input type="checkbox"/> |
| Chain of custody present? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | | |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | | |
| Chain of custody agrees with sample labels? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | | |
| Samples in proper container/bottle? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | | |
| Sample containers intact? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | | |
| Sufficient sample volume for indicated test? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | | |
| All samples received within holding time? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | | |
| Reported field parameters measured: | Field <input type="checkbox"/> | Lab <input type="checkbox"/> | NA | <input checked="" type="checkbox"/> | |
| Container/Temp Blank temperature in compliance? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | | |

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

- | | | | | |
|---|---|-----------------------------|-------------------|-------------------------------------|
| Water – at least one vial per sample has zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No VOA vials | <input checked="" type="checkbox"/> |
| Water - TOX containers have zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No TOX containers | <input checked="" type="checkbox"/> |
| Water - pH acceptable upon receipt? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | NA | <input type="checkbox"/> |
| NPDES/CWA TCN interferences checked/treated in the field? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | NA | <input checked="" type="checkbox"/> |

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

RMS

23121997/
23122018/231220
23122020

23121997

001	1-A	DRINKING WATER	LEAD	12/23/23 @ 1000
002	1-B	DRINKING WATER	LEAD	12/23/23 @ 1000
003	2-A	DRINKING WATER	LEAD	12/23/23 @ 1000
004	2-B	DRINKING WATER	LEAD	12/23/23 @ 1000
005	3-A	DRINKING WATER	LEAD	12/23/23 @ 1000
006	3-B	DRINKING WATER	LEAD	12/23/23 @ 1000
007	4-A	DRINKING WATER	LEAD	12/23/23 @ 1000
008	4-B	DRINKING WATER	LEAD	12/23/23 @ 1000
009	5-A	DRINKING WATER	LEAD	12/23/23 @ 1000
010	5-B	DRINKING WATER	LEAD	12/23/23 @ 1000
011	6-A	DRINKING WATER	LEAD	12/23/23 @ 1000
012	6-B	DRINKING WATER	LEAD	12/23/23 @ 1000
013	7-A	DRINKING WATER	LEAD	12/23/23 @ 1000
014	7-B	DRINKING WATER	LEAD	12/23/23 @ 1000
015	8-A	DRINKING WATER	LEAD	12/23/23 @ 1000
016	8-B	DRINKING WATER	LEAD	12/23/23 @ 1000
017	9-A	DRINKING WATER	LEAD	12/23/23 @ 1000
018	9-B	DRINKING WATER	LEAD	12/23/23 @ 1000
019	10-A	DRINKING WATER	LEAD	12/23/23 @ 1000
020	10-B	DRINKING WATER	LEAD	12/23/23 @ 1000
021	11-A	DRINKING WATER	LEAD	12/23/23 @ 1000
022	11-B	DRINKING WATER	LEAD	12/23/23 @ 1000
023	12-A	DRINKING WATER	LEAD	12/23/23 @ 1000
024	12-B	DRINKING WATER	LEAD	12/23/23 @ 1000
025	13-A	DRINKING WATER	LEAD	12/23/23 @ 1000
026	13-B	DRINKING WATER	LEAD	12/23/23 @ 1000
027	14-A	DRINKING WATER	LEAD	12/23/23 @ 1000
028	14-B	DRINKING WATER	LEAD	12/23/23 @ 1000
029	15-A	DRINKING WATER	LEAD	12/23/23 @ 1000
030	15-B	DRINKING WATER	LEAD	12/23/23 @ 1000
031	16-A	DRINKING WATER	LEAD	12/23/23 @ 1000
032	16-B	DRINKING WATER	LEAD	12/23/23 @ 1000
033	17-A	DRINKING WATER	LEAD	12/23/23 @ 1000
034	17-B	DRINKING WATER	LEAD	12/23/23 @ 1000
035	18-A	DRINKING WATER	LEAD	12/23/23 @ 1000
036	18-B	DRINKING WATER	LEAD	12/23/23 @ 1000
037	19-A	DRINKING WATER	LEAD	12/23/23 @ 1000
038	19-B	DRINKING WATER	LEAD	12/23/23 @ 1000
039	20-A	DRINKING WATER	LEAD	12/23/23 @ 1000
040	20-B	DRINKING WATER	LEAD	12/23/23 @ 1000
041	21-A	DRINKING WATER	LEAD	12/23/23 @ 1000
042	21-B	DRINKING WATER	LEAD	12/23/23 @ 1000
043	22-A	DRINKING WATER	LEAD	12/23/23 @ 1000
044	22-B	DRINKING WATER	LEAD	12/23/23 @ 1000
045	23-A	DRINKING WATER	LEAD	12/23/23 @ 1000
046	23-B	DRINKING WATER	LEAD	12/23/23 @ 1000
047	24-A	DRINKING WATER	LEAD	12/23/23 @ 1000

RMS

23121997/
2312018/2312016
2312020

23121997

048	24-B	DRINKING WATER	LEAD	12/23/23 @ 1000
049	25-A	DRINKING WATER	LEAD	12/23/23 @ 1000
050	25-B	DRINKING WATER	LEAD	12/23/23 @ 1000
051	26-A	DRINKING WATER	LEAD	12/23/23 @ 1000
052	26-B	DRINKING WATER	LEAD	12/23/23 @ 1000
053	27-A	DRINKING WATER	LEAD	12/23/23 @ 1000
054	27-B	DRINKING WATER	LEAD	12/23/23 @ 1000
055	28-A	DRINKING WATER	LEAD	12/23/23 @ 1000
056	28-B	DRINKING WATER	LEAD	12/23/23 @ 1000
057	29-A	DRINKING WATER	LEAD	12/23/23 @ 1000
058	29-B	DRINKING WATER	LEAD	12/23/23 @ 1000
059	30-A	DRINKING WATER	LEAD	12/23/23 @ 1000
060	30-B	DRINKING WATER	LEAD	12/23/23 @ 1000
061	31-A	DRINKING WATER	LEAD	12/23/23 @ 1000
062	31-B	DRINKING WATER	LEAD	12/23/23 @ 1000

2312018

063	32-A 001	DRINKING WATER	LEAD	12/23/23 @ 1000
064	32-B 002	DRINKING WATER	LEAD	12/23/23 @ 1000
065	33-A 003	DRINKING WATER	LEAD	12/23/23 @ 1000
066	33-B 004	DRINKING WATER	LEAD	12/23/23 @ 1000
067	34-A 005	DRINKING WATER	LEAD	12/23/23 @ 1000
068	34-B 006	DRINKING WATER	LEAD	12/23/23 @ 1000
069	35-A 007	DRINKING WATER	LEAD	12/23/23 @ 1000
070	35-B 008	DRINKING WATER	LEAD	12/23/23 @ 1000
071	36-A 009	DRINKING WATER	LEAD	12/23/23 @ 1000
072	36-B 010	DRINKING WATER	LEAD	12/23/23 @ 1000
073	37-A 011	DRINKING WATER	LEAD	12/23/23 @ 1000
074	37-B 012	DRINKING WATER	LEAD	12/23/23 @ 1000
075	38-A 013	DRINKING WATER	LEAD	12/23/23 @ 1000
076	38-B 014	DRINKING WATER	LEAD	12/23/23 @ 1000
077	39-A 015	DRINKING WATER	LEAD	12/23/23 @ 1000
078	39-B 016	DRINKING WATER	LEAD	12/23/23 @ 1000
079	40-A 017	DRINKING WATER	LEAD	12/23/23 @ 1000
080	40-B 018	DRINKING WATER	LEAD	12/23/23 @ 1000
081	41-A 019	DRINKING WATER	LEAD	12/23/23 @ 1000
082	41-B 020	DRINKING WATER	LEAD	12/23/23 @ 1000
083	42-A 021	DRINKING WATER	LEAD	12/23/23 @ 1000
084	42-B 022	DRINKING WATER	LEAD	12/23/23 @ 1000
085	43-A 023	DRINKING WATER	LEAD	12/23/23 @ 1000
086	43-B 024	DRINKING WATER	LEAD	12/23/23 @ 1000
087	44-A 025	DRINKING WATER	LEAD	12/23/23 @ 1000
088	44-B 026	DRINKING WATER	LEAD	12/23/23 @ 1000
089	45-A 027	DRINKING WATER	LEAD	12/23/23 @ 1000
090	45-B 028	DRINKING WATER	LEAD	12/23/23 @ 1000
091	46-A 029	DRINKING WATER	LEAD	12/23/23 @ 1000
092	46-B 030	DRINKING WATER	LEAD	12/23/23 @ 1000
093	47-A 031	DRINKING WATER	LEAD	12/23/23 @ 1000
094	47-B 032	DRINKING WATER	LEAD	12/23/23 @ 1000

JE
mm
1/1/23

RMS

23121997/
2312018/2312019/
23122020

23122018

033 48-A	DRINKING WATER	LEAD	12/23/23 @ 1000
034 48-B	DRINKING WATER	LEAD	12/23/23 @ 1000
035 49-A	DRINKING WATER	LEAD	12/23/23 @ 1000
036 49-B	DRINKING WATER	LEAD	12/23/23 @ 1000
037 50-A	DRINKING WATER	LEAD	12/23/23 @ 1000
038 50-B	DRINKING WATER	LEAD	12/23/23 @ 1000
039 51-A	DRINKING WATER	LEAD	12/23/23 @ 1000
040 51-B	DRINKING WATER	LEAD	12/23/23 @ 1000
041 52-A	DRINKING WATER	LEAD	12/23/23 @ 1000
042 52-B	DRINKING WATER	LEAD	12/23/23 @ 1000
043 53-A	DRINKING WATER	LEAD	12/23/23 @ 1000
044 53-B	DRINKING WATER	LEAD	12/23/23 @ 1000
045 54-A	DRINKING WATER	LEAD	12/23/23 @ 1000

JE
046 54-B
047 55-A
048
049 55-B

046 54-B	DRINKING WATER	LEAD	12/23/23 @ 1000
047 55-A	DRINKING WATER	LEAD	12/23/23 @ 1000
049 55-B	DRINKING WATER	LEAD	12/23/23 @ 1000
050 56-A	DRINKING WATER	LEAD	12/23/23 @ 1000
051 57-A	DRINKING WATER	LEAD	12/23/23 @ 1000
052 57-B	DRINKING WATER	LEAD	12/23/23 @ 1000
053 58-A	DRINKING WATER	LEAD	12/23/23 @ 1000
054 58-B	DRINKING WATER	LEAD	12/23/23 @ 1000
055 59-A	DRINKING WATER	LEAD	12/23/23 @ 1000
056 59-B	DRINKING WATER	LEAD	12/23/23 @ 1000
057 60-A	DRINKING WATER	LEAD	12/23/23 @ 1000
058 60-B	DRINKING WATER	LEAD	12/23/23 @ 1000
059 61-A	DRINKING WATER	LEAD	12/23/23 @ 1000
060 61-B	DRINKING WATER	LEAD	12/23/23 @ 1000
061 62-A	DRINKING WATER	LEAD	12/23/23 @ 1000
062 62-B	DRINKING WATER	LEAD	12/23/23 @ 1000

23122019

063-A	DRINKING WATER	LEAD	12/23/23 @ 1000
063-B	DRINKING WATER	LEAD	12/23/23 @ 1000
064-A	DRINKING WATER	LEAD	12/23/23 @ 1000
064-B	DRINKING WATER	LEAD	12/23/23 @ 1000
065-A	DRINKING WATER	LEAD	12/23/23 @ 1000
066 65-B	DRINKING WATER	LEAD	12/23/23 @ 1000
067 66-A	DRINKING WATER	LEAD	12/23/23 @ 1000
068 66-B	DRINKING WATER	LEAD	12/23/23 @ 1000
069 67-A	DRINKING WATER	LEAD	12/23/23 @ 1000
070 67-B	DRINKING WATER	LEAD	12/23/23 @ 1000
071 68-A	DRINKING WATER	LEAD	12/23/23 @ 1000
072 68-B	DRINKING WATER	LEAD	12/23/23 @ 1000
073 69-A	DRINKING WATER	LEAD	12/23/23 @ 1000
074 69-B	DRINKING WATER	LEAD	12/23/23 @ 1000
075 70-A	DRINKING WATER	LEAD	12/23/23 @ 1000
076 70-B	DRINKING WATER	LEAD	12/23/23 @ 1000
077 71-A	DRINKING WATER	LEAD	12/23/23 @ 1000
078 71-B	DRINKING WATER	LEAD	12/23/23 @ 1000

RMS

23121997/
2312018/2312019/
2312020

23122019

019 72-A	DRINKING WATER	LEAD	12/23/23 @ 1000
020 72-B	DRINKING WATER	LEAD	12/23/23 @ 1000
021 73-A	DRINKING WATER	LEAD	12/23/23 @ 1000
022 73-B	DRINKING WATER	LEAD	12/23/23 @ 1000
023 74-A	DRINKING WATER	LEAD	12/23/23 @ 1000
024 74-B	DRINKING WATER	LEAD	12/23/23 @ 1000
025 75-A	DRINKING WATER	LEAD	12/23/23 @ 1000
026 75-B	DRINKING WATER	LEAD	12/23/23 @ 1000
027 76-A	DRINKING WATER	LEAD	12/23/23 @ 1000
028 76-B	DRINKING WATER	LEAD	12/23/23 @ 1000
029 77-A	DRINKING WATER	LEAD	12/23/23 @ 1000
030 77-B	DRINKING WATER	LEAD	12/23/23 @ 1000
031 78-A	DRINKING WATER	LEAD	12/23/23 @ 1000
032 78-B	DRINKING WATER	LEAD	12/23/23 @ 1000
033 79-A	DRINKING WATER	LEAD	12/23/23 @ 1000
034 79-B	DRINKING WATER	LEAD	12/23/23 @ 1000
035 80-A	DRINKING WATER	LEAD	12/23/23 @ 1000
036 80-B	DRINKING WATER	LEAD	12/23/23 @ 1000
037 81-A	DRINKING WATER	LEAD	12/23/23 @ 1000
038 81-B	DRINKING WATER	LEAD	12/23/23 @ 1000
039 82-A	DRINKING WATER	LEAD	12/23/23 @ 1000
040 82-B	DRINKING WATER	LEAD	12/23/23 @ 1000
041 83-A	DRINKING WATER	LEAD	12/23/23 @ 1000
042 83-B	DRINKING WATER	LEAD	12/23/23 @ 1000
043 84-A	DRINKING WATER	LEAD	12/23/23 @ 1000
044 84-B	DRINKING WATER	LEAD	12/23/23 @ 1000
045 85-A	DRINKING WATER	LEAD	12/23/23 @ 1000
046 85-B	DRINKING WATER	LEAD	12/23/23 @ 1000
047 86-A	DRINKING WATER	LEAD	12/23/23 @ 1000
048 86-B	DRINKING WATER	LEAD	12/23/23 @ 1000
049 87-A	DRINKING WATER	LEAD	12/23/23 @ 1000
050 87-B	DRINKING WATER	LEAD	12/23/23 @ 1000
051 88-A	DRINKING WATER	LEAD	12/23/23 @ 1000
052 88-B	DRINKING WATER	LEAD	12/23/23 @ 1000
053 89-A	DRINKING WATER	LEAD	12/23/23 @ 1000
054 89-B	DRINKING WATER	LEAD	12/23/23 @ 1000
055 90-A	DRINKING WATER	LEAD	12/23/23 @ 1000
056 90-B	DRINKING WATER	LEAD	12/23/23 @ 1000
057 91-A	DRINKING WATER	LEAD	12/23/23 @ 1000
058 91-B	DRINKING WATER	LEAD	12/23/23 @ 1000
059 92-A	DRINKING WATER	LEAD	12/23/23 @ 1000
060 92-B	DRINKING WATER	LEAD	12/23/23 @ 1000
061 93-A	DRINKING WATER	LEAD	12/23/23 @ 1000
062 93-B	DRINKING WATER	LEAD	12/23/23 @ 1000

23122020 94-Acc1

002 94-B	DRINKING WATER	LEAD	12/23/23 @ 1000
003 95-A	DRINKING WATER	LEAD	12/23/23 @ 1000

RMS

23121997/
23122018/23122011
23122020

23122020

004 95-B	DRINKING WATER	LEAD	12/23/23 @ 1000
005 96-A	DRINKING WATER	LEAD	12/23/23 @ 1000
006 96-B	DRINKING WATER	LEAD	12/23/23 @ 1000
007 97-A	DRINKING WATER	LEAD	12/23/23 @ 1000
008 97-B	DRINKING WATER	LEAD	12/23/23 @ 1000
009 98-A	DRINKING WATER	LEAD	12/23/23 @ 1000
010 98-B	DRINKING WATER	LEAD	12/23/23 @ 1000
011 99-A	DRINKING WATER	LEAD	12/23/23 @ 1000
012 99-B	DRINKING WATER	LEAD	12/23/23 @ 1000
013 100-A	DRINKING WATER	LEAD	12/23/23 @ 1000
014 100-B	DRINKING WATER	LEAD	12/23/23 @ 1000
015 101-A	DRINKING WATER	LEAD	12/23/23 @ 1000
016 101-B	DRINKING WATER	LEAD	12/23/23 @ 1000
017 102-A	DRINKING WATER	LEAD	12/23/23 @ 1000
018 102-B	DRINKING WATER	LEAD	12/23/23 @ 1000
019 103-A	DRINKING WATER	LEAD	12/23/23 @ 1000
020 103-B	DRINKING WATER	LEAD	12/23/23 @ 1000
021 104-A	DRINKING WATER	LEAD	12/23/23 @ 1000
022 104-B	DRINKING WATER	LEAD	12/23/23 @ 1000
023 105-A	DRINKING WATER	LEAD	12/23/23 @ 1000
024 105-B	DRINKING WATER	LEAD	12/23/23 @ 1000
025 106-A	DRINKING WATER	LEAD	12/23/23 @ 1000
026 106-B	DRINKING WATER	LEAD	12/23/23 @ 1000
027 107-A	DRINKING WATER	LEAD	12/23/23 @ 1000
028 107-B	DRINKING WATER	LEAD	12/23/23 @ 1000
029 108-A	DRINKING WATER	LEAD	12/23/23 @ 1000
030 108-B	DRINKING WATER	LEAD	12/23/23 @ 1000
031 109-A	DRINKING WATER	LEAD	12/23/23 @ 1000
032 109-B	DRINKING WATER	LEAD	12/23/23 @ 1000
033 110-A	DRINKING WATER	LEAD	12/23/23 @ 1000
034 110-B	DRINKING WATER	LEAD	12/23/23 @ 1000
035 111-A	DRINKING WATER	LEAD	12/23/23 @ 1000
036 111-B	DRINKING WATER	LEAD	12/23/23 @ 1000
037 112-A	DRINKING WATER	LEAD	12/23/23 @ 1000
038 112-B	DRINKING WATER	LEAD	12/23/23 @ 1000
039 113-A	DRINKING WATER	LEAD	12/23/23 @ 1000
040 113-B	DRINKING WATER	LEAD	12/23/23 @ 1000
041 114-A	DRINKING WATER	LEAD	12/23/23 @ 1000
042 114-B	DRINKING WATER	LEAD	12/23/23 @ 1000
043 115-A	DRINKING WATER	LEAD	12/23/23 @ 1000
044 115-B	DRINKING WATER	LEAD	12/23/23 @ 1000
045 116-A	DRINKING WATER	LEAD	12/23/23 @ 1000
046 116-B	DRINKING WATER	LEAD	12/23/23 @ 1000
047 117-A	DRINKING WATER	LEAD	12/23/23 @ 1000
048 117-B	DRINKING WATER	LEAD	12/23/23 @ 1000
049 118-A	DRINKING WATER	LEAD	12/23/23 @ 1000
050 118-B	DRINKING WATER	LEAD	12/23/23 @ 1000

RMS

23/2020

OS1 119-A	DRINKING WATER	LEAD	12/23/23 @ 1000
OS2 119-B	DRINKING WATER	LEAD	12/23/23 @ 1000
OS3 120-A	DRINKING WATER	LEAD	12/23/23 @ 1000
OS4 120-B	DRINKING WATER	LEAD	12/23/23 @ 1000
OS5 121-A	DRINKING WATER	LEAD	12/23/23 @ 1000
OS6 121-B	DRINKING WATER	LEAD	12/23/23 @ 1000
OS7 122-A	DRINKING WATER	LEAD	12/23/23 @ 1000
OS8 122-B	DRINKING WATER	LEAD	12/23/23 @ 1000
OS9 123-A	DRINKING WATER	LEAD	12/23/23 @ 1000
<u>OS10 123-B</u>	DRINKING WATER	LEAD	12/23/23 @ 1000
end 124-A	DRINKING WATER	LEAD	12/23/23 @ 1000
124-B	DRINKING WATER	LEAD	12/23/23 @ 1000
125-A	DRINKING WATER	LEAD	12/23/23 @ 1000
125-B	DRINKING WATER	LEAD	12/23/23 @ 1000

23121997/
23/2018/23/2019/
23/2020