

January 11, 2024

John Cable
Triangle
17855 Elk Prairie Drive
P.O. Box 1026
Rolla, MO 65402
TEL: (573) 364-1864
FAX: (573) 364-4782



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: RPS-Truman Elementary

WorkOrder: 23122001

Dear John Cable:

TEKLAB, INC received 60 samples on 12/27/2023 2:30:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Marvin L. Darling
Project Manager
(618)344-1004 ex 41
mdarling@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122001

Client Project: RPS-Truman Elementary

Report Date: 11-Jan-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Quality Control Results	9
Receiving Check List	12
Chain of Custody	Appended

Client: Triangle

Work Order: 23122001

Client Project: RPS-Truman Elementary

Report Date: 11-Jan-24

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Triangle

Work Order: 23122001

Client Project: RPS-Truman Elementary

Report Date: 11-Jan-24

Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)



Case Narrative

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122001

Client Project: RPS-Truman Elementary

Report Date: 11-Jan-24

Cooler Receipt Temp: N/A °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com



Accreditations

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122001

Client Project: RPS-Truman Elementary

Report Date: 11-Jan-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122001

Client Project: RPS-Truman Elementary

Report Date: 11-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
23122001-001A	31-A	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 5:24	12/20/2023 11:00
23122001-002A	31-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 4:33	12/20/2023 11:00
23122001-003A	32-A	NELAP		0.0010	0.0043	mg/L	1	01/06/2024 4:37	12/20/2023 11:00
23122001-004A	32-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 4:54	12/20/2023 11:00
23122001-005A	33-A	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 4:58	12/20/2023 11:00
23122001-006A	33-B	NELAP		0.0010	0.0016	mg/L	1	01/06/2024 5:02	12/20/2023 11:00
23122001-007A	34-A	NELAP		0.0010	0.0012	mg/L	1	01/06/2024 5:07	12/20/2023 11:00
23122001-008A	34-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 5:11	12/20/2023 11:00
23122001-009A	35-A	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 5:15	12/20/2023 11:00
23122001-010A	35-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 5:19	12/20/2023 11:00
23122001-011A	36-A	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 5:49	12/20/2023 11:00
23122001-012A	36-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 5:53	12/20/2023 11:00
23122001-013A	37-A	NELAP		0.0010	0.0016	mg/L	1	01/06/2024 5:57	12/20/2023 11:00
23122001-014A	37-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 6:02	12/20/2023 11:00
23122001-015A	38-A	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 6:06	12/20/2023 11:00
23122001-016A	38-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 6:10	12/20/2023 11:00
23122001-017A	39-A	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 6:18	12/20/2023 11:00
23122001-018A	39-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 6:14	12/20/2023 11:00
23122001-019A	40-A	NELAP		0.0010	0.0013	mg/L	1	01/06/2024 6:44	12/20/2023 11:00
23122001-020A	40-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 6:48	12/20/2023 11:00
23122001-021A	41-A	NELAP		0.0010	0.0011	mg/L	1	01/06/2024 6:52	12/20/2023 11:00
23122001-022A	41-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 6:56	12/20/2023 11:00
23122001-023A	42-A	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 7:01	12/20/2023 11:00
23122001-024A	42-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 7:05	12/20/2023 11:00
23122001-025A	43-A	NELAP		0.0010	0.0075	mg/L	1	01/06/2024 7:09	12/20/2023 11:00
23122001-026A	43-B	NELAP		0.0010	0.0011	mg/L	1	01/06/2024 7:13	12/20/2023 11:00
23122001-027A	44-A	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 7:18	12/20/2023 11:00
23122001-028A	44-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 8:08	12/20/2023 11:00
23122001-029A	45-A	NELAP		0.0010	0.0027	mg/L	1	01/06/2024 8:13	12/20/2023 11:00
23122001-030A	45-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 8:17	12/20/2023 11:00
23122001-031A	46-A	NELAP		0.0010	0.0019	mg/L	1	01/06/2024 7:43	12/20/2023 11:00
23122001-032A	46-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 7:47	12/20/2023 11:00
23122001-033A	47-A	NELAP		0.0010	0.0013	mg/L	1	01/06/2024 7:51	12/20/2023 11:00
23122001-034A	47-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 7:56	12/20/2023 11:00
23122001-035A	48-A	NELAP		0.0010	0.0042	mg/L	1	01/06/2024 8:00	12/20/2023 11:00
23122001-036A	48-B	NELAP		0.0010	< 0.0010	mg/L	1	01/08/2024 11:33	12/20/2023 11:00
23122001-037A	49-A	NELAP		0.0010	0.0066	mg/L	1	01/06/2024 8:04	12/20/2023 11:00
23122001-038A	49-B	NELAP		0.0010	0.0013	mg/L	1	01/08/2024 11:04	12/20/2023 11:00
23122001-039A	50-A	NELAP		0.0010	0.0102	mg/L	1	01/08/2024 11:09	12/20/2023 11:00
23122001-040A	50-B	NELAP		0.0010	0.0017	mg/L	1	01/08/2024 12:23	12/20/2023 11:00
23122001-041A	51-A	NELAP		0.0010	< 0.0010	mg/L	1	01/09/2024 9:37	12/20/2023 11:00
23122001-042A	51-B	NELAP		0.0010	< 0.0010	mg/L	1	01/09/2024 9:41	12/20/2023 11:00
23122001-043A	52-A	NELAP		0.0010	< 0.0010	mg/L	1	01/09/2024 9:45	12/20/2023 11:00
23122001-044A	52-B	NELAP		0.0010	< 0.0010	mg/L	1	01/09/2024 9:49	12/20/2023 11:00
23122001-045A	53-A	NELAP		0.0010	< 0.0010	mg/L	1	01/08/2024 12:27	12/20/2023 11:00
23122001-046A	53-B	NELAP		0.0010	< 0.0010	mg/L	1	01/09/2024 9:53	12/20/2023 11:00
23122001-047A	54-A	NELAP		0.0010	0.0012	mg/L	1	01/09/2024 9:58	12/20/2023 11:00
23122001-048A	54-B	NELAP		0.0010	< 0.0010	mg/L	1	01/09/2024 10:02	12/20/2023 11:00



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122001

Client Project: RPS-Truman Elementary

Report Date: 11-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
23122001-049A	55-A	NELAP		0.0010	0.0015	mg/L	1	01/09/2024 10:06	12/20/2023 11:00
23122001-050A	55-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 3:59	12/20/2023 11:00
23122001-051A	56-A	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 4:03	12/20/2023 11:00
23122001-052A	56-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 4:08	12/20/2023 11:00
23122001-053A	57-A	NELAP		0.0010	0.0025	mg/L	1	01/06/2024 4:12	12/20/2023 11:00
23122001-054A	57-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 4:16	12/20/2023 11:00
23122001-055A	58-A	NELAP		0.0010	0.0015	mg/L	1	01/06/2024 4:20	12/20/2023 11:00
23122001-056A	58-B	NELAP		0.0010	< 0.0010	mg/L	1	01/06/2024 4:24	12/20/2023 11:00
23122001-057A	59-A	NELAP		0.0010	0.0024	mg/L	1	01/06/2024 4:29	12/20/2023 11:00
23122001-058A	59-B	NELAP		0.0010	< 0.0010	mg/L	1	01/08/2024 11:13	12/20/2023 11:00
23122001-059A	60-A	NELAP		0.0010	0.0033	mg/L	1	01/08/2024 11:17	12/20/2023 11:00
23122001-060A	60-B	NELAP		0.0010	< 0.0010	mg/L	1	01/08/2024 11:21	12/20/2023 11:00



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122001

Client Project: RPS-Truman Elementary

Report Date: 11-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216707		SampType: MBLK		Units mg/L							
SampID: MBLK-216707											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/05/2024	

Batch 216707		SampType: LCS		Units mg/L							
SampID: LCS-216707											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0504	0.0500	0	100.7	85	115	01/05/2024	

Batch 216707		SampType: MS		Units mg/L							
SampID: 23122001-045AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.122	0.1000	0.0006143	121.1	70	130	01/08/2024	

Batch 216707		SampType: MSD		Units mg/L							
SampID: 23122001-045AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.122	0.1000	0.0006143	121.8	0.1217	0.59	01/08/2024	

Batch 216707		SampType: MS		Units mg/L							
SampID: 23122001-049AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.100	0.1000	0.001454	98.9	70	130	01/09/2024	

Batch 216707		SampType: MSD		Units mg/L							
SampID: 23122001-049AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0985	0.1000	0.001454	97.1	0.1004	1.85	01/09/2024	

Batch 216708		SampType: MBLK		Units mg/L							
SampID: MBLK-216708											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/05/2024	

Batch 216708		SampType: LCS		Units mg/L							
SampID: LCS-216708											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0504	0.0500	0	100.7	85	115	01/05/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122001

Client Project: RPS-Truman Elementary

Report Date: 11-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216708		SampType: MS		Units mg/L							Date Analyzed
SampID: 23122001-001AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0953	0.1000	0.0005326	94.7	70	130	01/06/2024	

Batch 216708		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 23122001-001AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010	E	0.103	0.1000	0.0005326	102.1	0.09527	7.45	01/06/2024		

Batch 216708		SampType: MS		Units mg/L							Date Analyzed
SampID: 23122001-017AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0951	0.1000	0.0009234	94.1	70	130	01/06/2024	

Batch 216708		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 23122001-017AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010	E	0.101	0.1000	0.0009234	100.2	0.09506	6.17	01/06/2024		

Batch 216712		SampType: MBLK		Units mg/L							Date Analyzed
SampID: MBLK-216712											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/05/2024	

Batch 216712		SampType: LCS		Units mg/L							Date Analyzed
SampID: LCS-216712											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0504	0.0500	0	100.7	85	115	01/05/2024	

Batch 216712		SampType: MS		Units mg/L							Date Analyzed
SampID: 23122001-027AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0991	0.1000	0.0004581	98.7	70	130	01/06/2024	

Batch 216712		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 23122001-027AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010		0.0976	0.1000	0.0004581	97.2	0.09914	1.52	01/06/2024		



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122001

Client Project: RPS-Truman Elementary

Report Date: 11-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216712		SampType: MS		Units mg/L							
SampID: 23122001-036AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.117	0.1000	0.0009489	116.2	70	130	01/08/2024	

Batch 216712		SampType: MSD		Units mg/L							
SampID: 23122001-036AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.128	0.1000	0.0009489	126.8	0.1171	8.69	01/08/2024	

Batch 216716		SampType: MBLK		Units mg/L							
SampID: MBLK-216716											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/05/2024	

Batch 216716		SampType: LCS		Units mg/L							
SampID: LCS-216716											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0504	0.0500	0	100.7	85	115	01/05/2024	

Batch 216716		SampType: MS		Units mg/L							
SampID: 23122009-004AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.105	0.1000	0.001095	103.8	70	130	01/08/2024	

Batch 216716		SampType: MSD		Units mg/L							
SampID: 23122009-004AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.106	0.1000	0.001095	104.7	0.1049	0.81	01/08/2024	

Batch 216716		SampType: MS		Units mg/L							
SampID: 23122009-012AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.123	0.1000	0.001118	121.6	70	130	01/08/2024	

Batch 216716		SampType: MSD		Units mg/L							
SampID: 23122009-012AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.105	0.1000	0.001118	103.7	0.1227	15.70	01/08/2024	



Receiving Check List

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122001

Client Project: RPS-Truman Elementary

Report Date: 11-Jan-24

Carrier: John Cable

Received By: LEH

Completed by:

Amber Dilallo

Reviewed by:

Ellie Hopkins

On:

28-Dec-23

Amber Dilallo

On:

28-Dec-23

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

- | | | | | |
|---|--|------------------------------|--|----------------------------------|
| Shipping container/cooler in good condition? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | Not Present <input type="checkbox"/> | Temp °C N/A |
| Type of thermal preservation? | None <input checked="" type="checkbox"/> | Ice <input type="checkbox"/> | Blue Ice <input type="checkbox"/> | Dry Ice <input type="checkbox"/> |
| Chain of custody present? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody agrees with sample labels? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Samples in proper container/bottle? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sample containers intact? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sufficient sample volume for indicated test? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| All samples received within holding time? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Reported field parameters measured: | Field <input type="checkbox"/> | Lab <input type="checkbox"/> | NA <input checked="" type="checkbox"/> | |
| Container/Temp Blank temperature in compliance? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

- | | | | |
|---|---|-----------------------------|---|
| Water – at least one vial per sample has zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No VOA vials <input checked="" type="checkbox"/> |
| Water - TOX containers have zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No TOX containers <input checked="" type="checkbox"/> |
| Water - pH acceptable upon receipt? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | NA <input type="checkbox"/> |
| NPDES/CWA TCN interferences checked/treated in the field? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | NA <input checked="" type="checkbox"/> |

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

55-B received but not listen on CoC. - AMD/ERH 12/28/23

CHAIN OF CUSTODY

23122001

23121994

TEKLAB INC. 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

TE Em n25h

Client: TRIANGLE ENVIRONMENTAL SCIENCE AND ENGINEERING
 Address: PO BOX 1026
 City/State/Zip: ROLLA, MO 65402
 Contact: JOHN CABLE Phone: 573 308 0140
 Email: TRIANGLE.ENVIRONMENTAL Fax: @GMAIL.COM

Samples on: ICE BLUE ICE NO ICE NIA °C
 Preserved In: LAB FIELD FOR LAB USE ONLY

LAB NOTES:
55-B received not listed. Em n25h23

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply: Yes No
 Are these samples known to be hazardous? Yes No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section: Yes No

PROJECT NAME/NUMBER: RPS-Truman ELEMENTARY
 SAMPLE COLLECTOR'S NAME: JOHN W CABLE

and Type of Containers INDICATE ANALYSIS REQUESTED

RESULTS REQUESTED: Standard 1-2 Day (100% Surcharge) Other 3 Day (50% Surcharge)
 BILLING INSTRUCTIONS: TRIANGLE

UNP	HNO3	NaOH	H2SO4	HCL	MeOH	NAHSO4	TSP	Other	INDICATE ANALYSIS REQUESTED																				
								<u>LEAD</u>																					

Lab Use Only	Sample ID	Date/Time Sampled	Matrix
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water

Relinquished By	Date/Time	Received By	Date/Time
<u>JOHN W CABLE</u> <i>JWC</i>	<u>12/27/23 @ 1930</u>	<i>Laura Hanson</i>	<u>12/27/23 1430</u>

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

Truman

23121994 /
23122001 / 23122002

3121994

001	1-A	DRINKING WATER	LEAD	12/20/23 @ 1100
002	1-B	DRINKING WATER	LEAD	12/20/23 @ 1100
003	2-A	DRINKING WATER	LEAD	12/20/23 @ 1100
004	2-B	DRINKING WATER	LEAD	12/20/23 @ 1100
005	3-A	DRINKING WATER	LEAD	12/20/23 @ 1100
006	3-B	DRINKING WATER	LEAD	12/20/23 @ 1100
007	4-A	DRINKING WATER	LEAD	12/20/23 @ 1100
008	4-B	DRINKING WATER	LEAD	12/20/23 @ 1100
009	5-A	DRINKING WATER	LEAD	12/20/23 @ 1100
010	5-B	DRINKING WATER	LEAD	12/20/23 @ 1100
011	6-A	DRINKING WATER	LEAD	12/20/23 @ 1100
012	6-B	DRINKING WATER	LEAD	12/20/23 @ 1100
013	7-A	DRINKING WATER	LEAD	12/20/23 @ 1100
014	7-B	DRINKING WATER	LEAD	12/20/23 @ 1100
015	8-A	DRINKING WATER	LEAD	12/20/23 @ 1100
016	8-B	DRINKING WATER	LEAD	12/20/23 @ 1100
017	9-A	DRINKING WATER	LEAD	12/20/23 @ 1100
018	9-B	DRINKING WATER	LEAD	12/20/23 @ 1100
019	10-A	DRINKING WATER	LEAD	12/20/23 @ 1100
020	10-B	DRINKING WATER	LEAD	12/20/23 @ 1100
021	11-A	DRINKING WATER	LEAD	12/20/23 @ 1100
022	11-B	DRINKING WATER	LEAD	12/20/23 @ 1100
023	12-A	DRINKING WATER	LEAD	12/20/23 @ 1100
024	12-B	DRINKING WATER	LEAD	12/20/23 @ 1100
025	13-A	DRINKING WATER	LEAD	12/20/23 @ 1100
026	13-B	DRINKING WATER	LEAD	12/20/23 @ 1100
027	14-A	DRINKING WATER	LEAD	12/20/23 @ 1100
028	14-B	DRINKING WATER	LEAD	12/20/23 @ 1100
029	15-A	DRINKING WATER	LEAD	12/20/23 @ 1100
030	15-B	DRINKING WATER	LEAD	12/20/23 @ 1100
031	16-A	DRINKING WATER	LEAD	12/20/23 @ 1100
032	16-B	DRINKING WATER	LEAD	12/20/23 @ 1100
033	17-A	DRINKING WATER	LEAD	12/20/23 @ 1100
034	17-B	DRINKING WATER	LEAD	12/20/23 @ 1100
035	18-A	DRINKING WATER	LEAD	12/20/23 @ 1100
036	18-B	DRINKING WATER	LEAD	12/20/23 @ 1100
037	19-A	DRINKING WATER	LEAD	12/20/23 @ 1100
038	19-B	DRINKING WATER	LEAD	12/20/23 @ 1100
039	20-A	DRINKING WATER	LEAD	12/20/23 @ 1100
040	20-B	DRINKING WATER	LEAD	12/20/23 @ 1100
041	21-A	DRINKING WATER	LEAD	12/20/23 @ 1100
042	21-B	DRINKING WATER	LEAD	12/20/23 @ 1100
043	22-A	DRINKING WATER	LEAD	12/20/23 @ 1100
044	22-B	DRINKING WATER	LEAD	12/20/23 @ 1100
045	23-A	DRINKING WATER	LEAD	12/20/23 @ 1100
046	23-B	DRINKING WATER	LEAD	12/20/23 @ 1100
047	24-A	DRINKING WATER	LEAD	12/20/23 @ 1100

Truman

23121994/
23122001/23122002

23121994

048	24-B	DRINKING WATER	LEAD	12/20/23 @ 1100
049	25-A	DRINKING WATER	LEAD	12/20/23 @ 1100
050	25-B	DRINKING WATER	LEAD	12/20/23 @ 1100
051	26-A	DRINKING WATER	LEAD	12/20/23 @ 1100
052	26-B	DRINKING WATER	LEAD	12/20/23 @ 1100
053	27-A	DRINKING WATER	LEAD	12/20/23 @ 1100
054	27-B	DRINKING WATER	LEAD	12/20/23 @ 1100
055	28-A	DRINKING WATER	LEAD	12/20/23 @ 1100
056	28-B	DRINKING WATER	LEAD	12/20/23 @ 1100
057	29-A	DRINKING WATER	LEAD	12/20/23 @ 1100
058	29-B	DRINKING WATER	LEAD	12/20/23 @ 1100
059	30-A	DRINKING WATER	LEAD	12/20/23 @ 1100
060	30-B	DRINKING WATER	LEAD	12/20/23 @ 1100
001	31-A	DRINKING WATER	LEAD	12/20/23 @ 1100
002	31-B	DRINKING WATER	LEAD	12/20/23 @ 1100
003	32-A	DRINKING WATER	LEAD	12/20/23 @ 1100
004	32-B	DRINKING WATER	LEAD	12/20/23 @ 1100
005	33-A	DRINKING WATER	LEAD	12/20/23 @ 1100
006	33-B	DRINKING WATER	LEAD	12/20/23 @ 1100
007	34-A	DRINKING WATER	LEAD	12/20/23 @ 1100
008	34-B	DRINKING WATER	LEAD	12/20/23 @ 1100
009	35-A	DRINKING WATER	LEAD	12/20/23 @ 1100
010	35-B	DRINKING WATER	LEAD	12/20/23 @ 1100
011	36-A	DRINKING WATER	LEAD	12/20/23 @ 1100
012	36-B	DRINKING WATER	LEAD	12/20/23 @ 1100
013	37-A	DRINKING WATER	LEAD	12/20/23 @ 1100
014	37-B	DRINKING WATER	LEAD	12/20/23 @ 1100
015	38-A	DRINKING WATER	LEAD	12/20/23 @ 1100
016	38-B	DRINKING WATER	LEAD	12/20/23 @ 1100
017	39-A	DRINKING WATER	LEAD	12/20/23 @ 1100
018	39-B	DRINKING WATER	LEAD	12/20/23 @ 1100
019	40-A	DRINKING WATER	LEAD	12/20/23 @ 1100
020	40-B	DRINKING WATER	LEAD	12/20/23 @ 1100
021	41-A	DRINKING WATER	LEAD	12/20/23 @ 1100
022	41-B	DRINKING WATER	LEAD	12/20/23 @ 1100
023	42-A	DRINKING WATER	LEAD	12/20/23 @ 1100
024	42-B	DRINKING WATER	LEAD	12/20/23 @ 1100
025	43-A	DRINKING WATER	LEAD	12/20/23 @ 1100
026	43-B	DRINKING WATER	LEAD	12/20/23 @ 1100
027	44-A	DRINKING WATER	LEAD	12/20/23 @ 1100
028	44-B	DRINKING WATER	LEAD	12/20/23 @ 1100
029	45-A	DRINKING WATER	LEAD	12/20/23 @ 1100
030	45-B	DRINKING WATER	LEAD	12/20/23 @ 1100
031	46-A	DRINKING WATER	LEAD	12/20/23 @ 1100
032	46-B	DRINKING WATER	LEAD	12/20/23 @ 1100
033	47-A	DRINKING WATER	LEAD	12/20/23 @ 1100
034	47-B	DRINKING WATER	LEAD	12/20/23 @ 1100

Truman

23121994/
23122001/23122002

23122001				
035	48-A	DRINKING WATER	LEAD	12/20/23 @ 1100
036	48-B	DRINKING WATER	LEAD	12/20/23 @ 1100
037	49-A	DRINKING WATER	LEAD	12/20/23 @ 1100
038	49-B	DRINKING WATER	LEAD	12/20/23 @ 1100
039	50-A	DRINKING WATER	LEAD	12/20/23 @ 1100
040	50-B	DRINKING WATER	LEAD	12/20/23 @ 1100
041	51-A	DRINKING WATER	LEAD	12/20/23 @ 1100
042	51-B	DRINKING WATER	LEAD	12/20/23 @ 1100
043	52-A	DRINKING WATER	LEAD	12/20/23 @ 1100
044	52-B	DRINKING WATER	LEAD	12/20/23 @ 1100
045	53-A	DRINKING WATER	LEAD	12/20/23 @ 1100
046	53-B	DRINKING WATER	LEAD	12/20/23 @ 1100
047	54-A	DRINKING WATER	LEAD	12/20/23 @ 1100
048	54-B	DRINKING WATER	LEAD	12/20/23 @ 1100
049	55-A	DRINKING WATER	LEAD	12/20/23 @ 1100
050	55-B	DRINKING WATER	LEAD	12/20/23 @ 1100
051	56-A	DRINKING WATER	LEAD	12/20/23 @ 1100
052	56-B	DRINKING WATER	LEAD	12/20/23 @ 1100
053	57-A	DRINKING WATER	LEAD	12/20/23 @ 1100
054	57-B	DRINKING WATER	LEAD	12/20/23 @ 1100
055	58-A	DRINKING WATER	LEAD	12/20/23 @ 1100
056	58-B	DRINKING WATER	LEAD	12/20/23 @ 1100
057	59-A	DRINKING WATER	LEAD	12/20/23 @ 1100
058	59-B	DRINKING WATER	LEAD	12/20/23 @ 1100
059	60-A	DRINKING WATER	LEAD	12/20/23 @ 1100
060	60-B	DRINKING WATER	LEAD	12/20/23 @ 1100
061	61-A	DRINKING WATER	LEAD	12/20/23 @ 1100
062	61-B	DRINKING WATER	LEAD	12/20/23 @ 1100
063	62-A	DRINKING WATER	LEAD	12/20/23 @ 1100
064	62-B	DRINKING WATER	LEAD	12/20/23 @ 1100
065	63-A	DRINKING WATER	LEAD	12/20/23 @ 1100
066	63-B	DRINKING WATER	LEAD	12/20/23 @ 1100
067	64-A	DRINKING WATER	LEAD	12/20/23 @ 1100
068	64-B	DRINKING WATER	LEAD	12/20/23 @ 1100
069	65-A	DRINKING WATER	LEAD	12/20/23 @ 1100
070	65-B	DRINKING WATER	LEAD	12/20/23 @ 1100
071	66-A	DRINKING WATER	LEAD	12/20/23 @ 1100
072	66-B	DRINKING WATER	LEAD	12/20/23 @ 1100
073	67-A	DRINKING WATER	LEAD	12/20/23 @ 1100
074	67-B	DRINKING WATER	LEAD	12/20/23 @ 1100
075	68-A	DRINKING WATER	LEAD	12/20/23 @ 1100
076	68-B	DRINKING WATER	LEAD	12/20/23 @ 1100
077	69-A	DRINKING WATER	LEAD	12/20/23 @ 1100
078	69-B	DRINKING WATER	LEAD	12/20/23 @ 1100
079	70-A	DRINKING WATER	LEAD	12/20/23 @ 1100
080	70-B	DRINKING WATER	LEAD	12/20/23 @ 1100
081	71-A	DRINKING WATER	LEAD	12/20/23 @ 1100
082	71-B	DRINKING WATER	LEAD	12/20/23 @ 1100

end

Ruman

6-121979
TF 8m
1/18/23

72-A	DRINKING WATER	LEAD	12/20/23 @ 1100
72-B	DRINKING WATER	LEAD	12/20/23 @ 1100
73-A	DRINKING WATER	LEAD	12/20/23 @ 1100
73-B	DRINKING WATER	LEAD	12/20/23 @ 1100
74-A	DRINKING WATER	LEAD	12/20/23 @ 1100
74-B	DRINKING WATER	LEAD	12/20/23 @ 1100
75-A	DRINKING WATER	LEAD	12/20/23 @ 1100
75-B	DRINKING WATER	LEAD	12/20/23 @ 1100
76-A	DRINKING WATER	LEAD	12/20/23 @ 1100
76-B	DRINKING WATER	LEAD	12/20/23 @ 1100
77-A	DRINKING WATER	LEAD	12/20/23 @ 1100
77-B	DRINKING WATER	LEAD	12/20/23 @ 1100
78-A	DRINKING WATER	LEAD	12/20/23 @ 1100
78-B	DRINKING WATER	LEAD	12/20/23 @ 1100
79-A	DRINKING WATER	LEAD	12/20/23 @ 1100
79-B	DRINKING WATER	LEAD	12/20/23 @ 1100
80-A	DRINKING WATER	LEAD	12/20/23 @ 1100
80-B	DRINKING WATER	LEAD	12/20/23 @ 1100
81-A	DRINKING WATER	LEAD	12/20/23 @ 1100
81-B	DRINKING WATER	LEAD	12/20/23 @ 1100
82-A	DRINKING WATER	LEAD	12/20/23 @ 1100
82-B	DRINKING WATER	LEAD	12/20/23 @ 1100
83-A	DRINKING WATER	LEAD	12/20/23 @ 1100
83-B	DRINKING WATER	LEAD	12/20/23 @ 1100
84-A	DRINKING WATER	LEAD	12/20/23 @ 1100
84-B	DRINKING WATER	LEAD	12/20/23 @ 1100
85-A	DRINKING WATER	LEAD	12/20/23 @ 1100
85-B	DRINKING WATER	LEAD	12/20/23 @ 1100
86-A	DRINKING WATER	LEAD	12/20/23 @ 1100
86-B	DRINKING WATER	LEAD	12/20/23 @ 1100
87-A	DRINKING WATER	LEAD	12/20/23 @ 1100
87-B	DRINKING WATER	LEAD	12/20/23 @ 1100
88-A	DRINKING WATER	LEAD	12/20/23 @ 1100
88-B	DRINKING WATER	LEAD	12/20/23 @ 1100
89-A	DRINKING WATER	LEAD	12/20/23 @ 1100
89-B	DRINKING WATER	LEAD	12/20/23 @ 1100
90-A	DRINKING WATER	LEAD	12/20/23 @ 1100
90-B	DRINKING WATER	LEAD	12/20/23 @ 1100
91-A	DRINKING WATER	LEAD	12/20/23 @ 1100
91-B	DRINKING WATER	LEAD	12/20/23 @ 1100
92-A	DRINKING WATER	LEAD	12/20/23 @ 1100
92-B	DRINKING WATER	LEAD	12/20/23 @ 1100
93-A	DRINKING WATER	LEAD	12/20/23 @ 1100
93-B	DRINKING WATER	LEAD	12/20/23 @ 1100
94-A	DRINKING WATER	LEAD	12/20/23 @ 1100
94-B	DRINKING WATER	LEAD	12/20/23 @ 1100
95-A	DRINKING WATER	LEAD	12/20/23 @ 1100

Truman

23121774
TE GM
12/28/23

95-B	DRINKING WATER	LEAD	12/20/23 @ 1100
96-A	DRINKING WATER	LEAD	12/20/23 @ 1100
96-B	DRINKING WATER	LEAD	12/20/23 @ 1100
97-A	DRINKING WATER	LEAD	12/20/23 @ 1100
97-B	DRINKING WATER	LEAD	12/20/23 @ 1100
98-A	DRINKING WATER	LEAD	12/20/23 @ 1100
98-B	DRINKING WATER	LEAD	12/20/23 @ 1100
99-A	DRINKING WATER	LEAD	12/20/23 @ 1100
99-B	DRINKING WATER	LEAD	12/20/23 @ 1100
100-A	DRINKING WATER	LEAD	12/20/23 @ 1100
100-B	DRINKING WATER	LEAD	12/20/23 @ 1100
101-A	DRINKING WATER	LEAD	12/20/23 @ 1100
101-B	DRINKING WATER	LEAD	12/20/23 @ 1100
102-A	DRINKING WATER	LEAD	12/20/23 @ 1100
102-B	DRINKING WATER	LEAD	12/20/23 @ 1100
103-A	DRINKING WATER	LEAD	12/20/23 @ 1100
103-B	DRINKING WATER	LEAD	12/20/23 @ 1100
104-A	DRINKING WATER	LEAD	12/20/23 @ 1100
104-B	DRINKING WATER	LEAD	12/20/23 @ 1100
105-A	DRINKING WATER	LEAD	12/20/23 @ 1100
105-B	DRINKING WATER	LEAD	12/20/23 @ 1100
106-A	DRINKING WATER	LEAD	12/20/23 @ 1100
106-B	DRINKING WATER	LEAD	12/20/23 @ 1100
107-A	DRINKING WATER	LEAD	12/20/23 @ 1100
107-B	DRINKING WATER	LEAD	12/20/23 @ 1100
108-A	DRINKING WATER	LEAD	12/20/23 @ 1100
108-B	DRINKING WATER	LEAD	12/20/23 @ 1100
109-A	DRINKING WATER	LEAD	12/20/23 @ 1100
109-B	DRINKING WATER	LEAD	12/20/23 @ 1100
110-A	DRINKING WATER	LEAD	12/20/23 @ 1100
110-B	DRINKING WATER	LEAD	12/20/23 @ 1100
111-A	DRINKING WATER	LEAD	12/20/23 @ 1100
111-B	DRINKING WATER	LEAD	12/20/23 @ 1100
112-A	DRINKING WATER	LEAD	12/20/23 @ 1100
112-B	DRINKING WATER	LEAD	12/20/23 @ 1100
113-A	DRINKING WATER	LEAD	12/20/23 @ 1100
113-B	DRINKING WATER	LEAD	12/20/23 @ 1100
114-A	DRINKING WATER	LEAD	12/20/23 @ 1100
114-B	DRINKING WATER	LEAD	12/20/23 @ 1100
115-A	DRINKING WATER	LEAD	12/20/23 @ 1100
115-B	DRINKING WATER	LEAD	12/20/23 @ 1100
116-A	DRINKING WATER	LEAD	12/20/23 @ 1100
116-B	DRINKING WATER	LEAD	12/20/23 @ 1100
117-A	DRINKING WATER	LEAD	12/20/23 @ 1100
117-B	DRINKING WATER	LEAD	12/20/23 @ 1100
118-A	DRINKING WATER	LEAD	12/20/23 @ 1100
118-B	DRINKING WATER	LEAD	12/20/23 @ 1100

Truman

23121494
TE GM 12/28/23

119-A	DRINKING WATER	LEAD	12/20/23 @ 1100
119-B	DRINKING WATER	LEAD	12/20/23 @ 1100
120-A	DRINKING WATER	LEAD	12/20/23 @ 1100
120-B	DRINKING WATER	LEAD	12/20/23 @ 1100
121-A	DRINKING WATER	LEAD	12/20/23 @ 1100
121-B	DRINKING WATER	LEAD	12/20/23 @ 1100
122-A	DRINKING WATER	LEAD	12/20/23 @ 1100
122-B	DRINKING WATER	LEAD	12/20/23 @ 1100
123-A	DRINKING WATER	LEAD	12/20/23 @ 1100
123-B	DRINKING WATER	LEAD	12/20/23 @ 1100
124-A	DRINKING WATER	LEAD	12/20/23 @ 1100
124-B	DRINKING WATER	LEAD	12/20/23 @ 1100
125-A	DRINKING WATER	LEAD	12/20/23 @ 1100
125-B	DRINKING WATER	LEAD	12/20/23 @ 1100